

OUTDOOR PASSIVE INFRARED DETECTOR

LX-402, LX-802N

120° wide Long Range



FEATURES

- LX-402 :40ft.(12m) 120° Wide Angle
- LX-802N:80ft.(24m) Long Range
- Selectable Detection Area Patterns
- Day/Night Mode
- Waterproof (IP Rating:IP54)

FUNCTION

- Selectable Pulse Count (TEST or 2)
- Selectable Sensitivity (H , M or L)
- Form C Relay Output
- Tamper Switch

OPTION

- Ceiling Mount Bracket : CA-2C
- Multi-Angle Wall Mount Bracket :CA-1W
Adjust ±45° (Horizontally)
Adjust 0 - 20° (Vertically downwards)

Safety-Related Precautions

- Before installation, make sure to read this instruction manual carefully for safe and effective product operation.
- After reading this installation instructions, make sure to keep it in a convenient place for future use.

Warning	This icon denotes a situation involving the risk of serious injury or even death, if the warning given is ignored.	Caution	This icon denotes a situation involving the risk of serious injury or damage to property if the warning given is ignored.
----------------	--	----------------	---

- This icon indicates actions to be avoided. Details of the actions to be avoided are written beside or near icon.
- This icon indicates instructions that should be strictly followed.

Warning			
Never use this product for any application except purpose for detecting moving object such as human or car. In addition, never use for any activation for a shutter or other. It may cause hazards.		To avoid the risk of electric shock, never touch the main body of the product with wet hands (Also, if the product is wet after rain, do not touch it).	
Never attempt to disassemble or modify the product, which increases the risk of fire or damage of the product.		Never connect the terminal with higher power supply or current draw over the specification. It increases the risk of fire or damage to the product.	
Caution			
Avoid applying water directly from brackets, houses, or otherwise splashing water directly onto the product. It increases the risk of damaging the product.		Clean and inspect the device periodically for safe operation. If any defect is detected, ask your local shop to repair the device.	

1.INSTALLATION HINTS

Maximum mounting height is 8.3ft.(2.5m).

Mount the detector directly to a wall or ceiling with the optional bracket(model CA-1W or CA-2C).

Avoid moving objects in the detection area (i.e.swaying trees, bushes, etc.).



Aim the detector at wall or the ground, to avoid unwanted detection.

When using the pet alley area, the mounting height should be between 4-5ft.(1.2-1.5m).

Avoid looking directly at air conditioning or heating vents.


Avoid vapor or high humidity that can cause condensation.

2.DETECTION AREA PATTERNS



This product detects temperature differences between the mo background temperature in the detection area. So, if the object the detector can not detect it, and changing of the temperatur affect the detector's detection range. Additionally, since this product has directional characteristic it the target that is approaching the detector.

3. DESCRIPTION AND OPERATION



4. INSTALLATION PROCEDURE

Installation on wall

- Loosen cover screw and remove cover.
- Pull wire through the back of the detector.
If angle adjustment is required, use the optional "CA-1W" mounting bracket.
- NOTE!**
If you have problems of wiring through the back of the detector, remove adjustment screw and remove the PCB from the base. (see illus.)
- Connect wires to terminals, as shown.
Power supply wires should not exceed the following lengths.

wires size	length
AWG22 (0.33 mm ²)	1070ft (320m)
AWG20 (0.52 mm ²)	1700ft (510m)
AWG18 (0.83 mm ²)	2700ft (820m)
- Set the Day/Night mode adjustment to the "24HR" setting (DAY).
Set Pulse Count to "TEST" mode. Adjust sensitivity setting (see section 6-2 and 3).
- Replace the cover and supply power to unit. After the warmup period is complete (approx. 60 sec.), conduct Walk Test.
The LED Indicator lights when the unit detects moving object.
- After conducting Walk Test. Set the Day/Night mode adjustment to the NORMAL position (-). (If night only operation is required, see section 6-1).
Set Pulse Count to the "2" position. (see section 6-1 and 2).
- After wiring, pack the provided sponge into the opening between each wire and the knockout hole.
Select HIGH, MEDIUM or LOW sensitivity (H, M, L). Fasten cover with the cover screw. (see section 6-3)

Installation on ceiling


- Install the bracket "CA-2C" on ceiling and pull wire.
Use optional ceiling mount bracket "CA-2C".
- Attach the LX-402/802N to the bracket and pull wire.

5. OPTIONAL BRACKETS

Note! Maximum mounting height is 8.3 ft (2.5m)


1. Ceiling Mount Bracket "CA-2C"

Adjust Horizontally : ±45° Adjust Vertically : 0° to 20° downward



2. Multi-Angle Wall Mount Bracket "CA-1W"

Adjust Horizontally : ±45° Adjust Vertically : 0° to 20° downward



6.SETTING AND ADJUSTMENT

1. Day/ Night Mode

Adjust the Day/Night Mode switch of the detector according to the brightness of the surrounding area.



NORMAL Position

: To have the standard detector function only during evening/night time, set the dial to the reference position (·).



: To have the detector begin to function while the surrounding area is lighter, turn the dial gradually to the DAY side.



: To have the detector function only after it has become dark, turn the dial gradually to the NIGHT side.



: To have the detector function at all time, or to perform a walk test, set the dial to the DAY position.

Unit is pre-set at "NORMAL" position.

2. Pulse Count Switch



"2" mode : Select "2" for normal applications. (STANDARD Position)



"TEST" mode : Select "TEST" mode when conducting WALK TEST , or for use in extremely stable environments.

Unit is pre-set at "2" position.

3. Sensitivity Switch



"M" : Use "M" position for normal applications. (STANDARD Position)



"H" : Use "H" Position when you need high sensitivity. (ex.Pet Alley Area)



"L" : Use "L" position in areas that may be unstable.

Unit is pre-set at "M" position.

7.DETECTION AREA ADJUSTMENT

Changing vertical detection area


1.Multi-Level Area



Use this area for normal applications.


Unit is pre-set at "Multi-Level" setting.

2.Pet Alley Area




Provide a horizontal detection pattern with no declination of zones, allowing pets to move through the area.


Selecting Pet Alley Pattern



Carefully loosen the adjustment screw.



Slide the cover down and fasten the screw at the "P" position.



Flip the Mirror to the upper position.


NOTE ! Sensitivity setting must be one step higher position when pet alley area is selected.

NOTE ! Pet Alley Area will not function if two changes are not performed.

Eliminating unwanted detection zones

(LX-402 only)

Unwanted detection zones can be eliminated by simply masking the lens with the provided masking strip, as follows:



Example : ZONE "a" can be eliminated by masking the lens at area "a" (see illus.).

8.TROUBLE SHOOTING


PROBLEM	PROBABLE CAUSE	REMEDY
LED does not light up.	Improper power supply voltage. (disconnection, low voltage)	Confirm the power supply is under specification.
	Wrong polarity	Switch positive and negative at terminal.
	The detector is in warm up period.	Wait for.(approx. 60 sec.)
	The Day/Night Mode Adjustment knob setting is inappropriate.	See section 6-1. Confirm the adjustment knob.
LED lights up even though no one is in detection area.	Incorrect detection area.	See section 2.
	Moving object within area. (curtain, wall hanging, etc.)	Remove the object from the detection area.
	Improper power supply voltage.	Confirm the power supply is under specification.
	The unit is detecting persons, cars or other objects beyond the set area.	Check the detection area.
The LED lights up, but there is no relay output	Temperature of object within area is changing rapidly (heater, air conditioning, etc.)	Remove the heat sources from the detection area.
	Relay contact is stuck or damaged due to overloading.	Check load of output. The unit needs repair or replacement.
	Faulty wiring.	Wire correctly.
	Alarm output connects to other devices as follows. when NC output is used :connect in parallel. when NO output is used :connect in series.	when NC output is used :connect in series. when NO output is used :connect in parallel.

9.SPECIFICATIONS

Model	LX-402	LX-802N
Detection method	Passive Infrared	
Detection area	40ft×50ft(12m×15m) 120°wide	80ft×6.6ft(24m×2m) Long range
Coverage	Multi-Level Area	40 zones
	Pet Alley Area	12 zones
Mounting height	Multi-Level Area	18 zones
	Pet Alley Area	4 zones
Detection speed	8.3ft (2.5m) max	
Sensitivity adjustment	4-5ft (1.2-1.5m)	
Detection speed	1-3.3ft/sec. (0.3-1.0m/sec.)	
Sensitivity adjustment	Selectable 3 position (H,M,L)	
LED indicator	LED lights during detection	
Alarm period	2±1 sec.(Delay timer)	
Alarm output	NC.NO.28V DC 0.2A max	
Tamper switch	Opens when cover removed.	
Pulse count	2 (20±5 sec.) or TEST(1 pulse)	
Day/Night Mode adjustment	Approx. 10 to 100,000 lux	
Warm up period	Approx. 60 sec.	
Power input	10.8-13.2VDC	
Current draw	25 mA max	
Mounting	Wall (Indoor/Outdoor)	
Operating temperature	-4°F - +122°F(-20°C - +50°C)	
Environment humidity	95% max	
Weight	6.0oz (170g)	6.8oz (190g)
IP Rating	IP54	
Accessory	Masking strips (LX-402 only),Mounting screw,Sponge	

※ Specifications may be changed without prior notice for improvements.

10.DIMENSIONS



LX-402

LX-802N

inches(mm)

NOTE

This unit is designed to detect moving object and activate an alarm control panel. Being only part of a complete alarm system, we cannot accept responsibility for any damages or other consequences resulting from an intrusion.

This Product conforms to the EMC Directive.89/336 EEC.

This product is NOT a human detector of security purpose.

We recommend our other detectors of security purpose, if you would like to use detector for security purpose.



OPTEX CO., LTD. (ISO 9001 Certified by LRQA)
4-7-5 Nionohama Otsu, 520-0801 Japan
TEL (077)524-6047 FAX (077)522-9022

OPTEX INCORPORATED
1845W. 205th Street Torrance, CA 90501-1510 U.S.A.
TEL (310)533-1500 FAX (310)533-5910

OPTEX (EUROPE) LTD. (ISO 9002 Certified by NQA)
Clivemont Road, Cordwallis Park, Maidenhead, Berkshire, SL6 7BU U.K.
TEL (01628)631000 FAX (01628)636311